

CERTIFICATE

No. Z10 04 02 42206 007



Holder of Certificate: ABB SACE S.p.A.

Via Statale 113

I - 22016 Lenno (Co)

Italy

Factory(ies): 42206

Certification Mark:



Product: Safety Related Programmable Electronic System

Model(s): SAFETY 2600T PRESSURE TRANSMITTERS

Parameters:

Structure - Safety Integrity Level:	1oo1 - SIL2
Pressure range:	0 to 30000 kPa
Nominal current range:	4 to 20 mA
Transmitter failure mode:	<3.7 or >22 mA
Compliance voltage:	10.5 to 42 Vdc
Operating temperature range:	-40° C to +85° C

Tested according to:

- IEC 61508:1998...2000 / SIL2
- IEC 60068-2*:1974...1990
- IEC 529:1989
- EN 61000-4*:1993...1996
- EN 55011:1998
- EN 55022:1998

The listed product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report No. AL63021C; E-(Z10 02 08 42206 005)

Date: 2004-02-20

