



中国国家强制性产品认证证书

证书编号: 2010010302445951

委托人名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA(芬兰)

生产者(制造商)名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA(芬兰)

生产企业名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA(芬兰)

产品名称和系列、规格、型号

隔离开关熔断器组

OS1200L_, OS1250D_, OS1250B_, OS1250DA_; 型号规格见附件

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2010年11月30日

有效期至: 2015年11月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0338091



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2010010302445951

纸号: 338091

型号: OS1200L, OS1250D, OS1250B, OS1250DA;

额定绝缘电压(Ui): AC1000V;

约定发热电流(Ith): 1200A(OS1200L), 1250A(OS1250D, OS1250B, OS1250DA);

Ue/Ie:

AC-21A: 415V/1250A(OS1250D, OS1250B, OS1250DA)

AC-22A: 415V/1250A(OS1250D, OS1250B, OS1250DA)

AC-23A: 415V/1000A(OS1250D, OS1250B, OS1250DA)

AC-21B: 690V/1250A(OS1250D, OS1250B, OS1250DA), 600V/1200A(OS1200L)

AC-22B: 690V/1250A(OS1250D, OS1250B, OS1250DA), 600V/1200A(OS1200L)

AC-23B: 690V/1000A(OS1250D, OS1250B, OS1250DA), 600V/1000A(OS1200L)

额定限制短路电流:

2P: 500V/100kA, 690V/80kA(OS1250D, OS1250B, OS1250DA)

600V/100kA(OS1200L);

3P: 500V/80kA, 690V/80kA(OS1250D, OS1250B, OS1250DA)

600V/100kA(OS1200L);

4P: 500V/100kA, 690V/80kA(OS1250D, OS1250B, OS1250DA)

600V/100kA(OS1200L);

使用类别: AC-21A, AC-22A, AC-23A, AC-21B, AC-22B, AC-23B;

极数: 2P, 3P, 4P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010302445951

NAME AND ADDRESS OF THE APPLICANT

ABB Oy, Low Voltage Products
Muottitie 2A, P.O.Box 622, FIN-65101 VAASA, Finland

NAME AND ADDRESS OF THE MANUFACTURER

ABB Oy, Low Voltage Products
Muottitie 2A, P.O.Box 622, FIN-65101 VAASA, Finland

NAME AND ADDRESS OF THE FACTORY

ABB Oy, Low Voltage Products
Muottitie 2A, P.O.Box 622, FIN-65101 VAASA, Finland

NAME, MODEL AND SPECIFICATION

Switch-Disconnecter-fuse
OS1200L_, OS1250D_, OS1250B_, OS1250DA_ ; Model and specification see the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Nov. 30, 2010 Date of expiry: Nov. 30, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0338091