



中国国家强制性产品认证证书

证书编号: 2003010307099875

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123Heidelberg Germany

生产者(制造商)名称、地址

Siemens AG, I IA CE
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

生产企业名称、地址

Siemens AG, I IA CE
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

产品名称和系列、规格、型号

塑料外壳式断路器

MS450, MS451, M0450; 具体型号参数见附件

产品标准和技术要求

GB14048.2-2008、GB14048.4-2003

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2011年08月16日

有效期至: 2016年03月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2003年12月12日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0433853



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2003010307099875

纸号: 433853

MS450, MS451, MO450

额定绝缘电压(Ui): AC690V;

额定工作电压(Ue): AC400V, AC690V;

额定工作电流(Ie): 11-16A, 14-20A, 18-25A, 22-32A, 28-40A, 36-45A, 40-50A;

过电流脱扣器类型: 热磁式;

400V: Ics=25kA, Icu=50kA(16-25A); Ics=25kA, Icu=50kA(32-50A);

690V: Ics=3kA, Icu=5kA(16-25A); Ics=2kA, Icu=4kA(32-50A);

使用类别: A 类;

极数: 3P;

配用的辅助触头: 见下表

Cat-No	AC15	AC12	DC13	Ith	Fuse
SK4-11 HKS4-11 HKS4-20 HKS4-02	24V 6A 220V 4A 230V 4A 400V 3A 690V 1A	24V 10A 220V 10A 230V 10A 690V 10A	24V 2A 110V 0.5A 220V 0.25A 230V 0.25A	10A	gLgG 10A
HK4-W	24V 4A 230V 3A	24V 10A 220V 10A 230V 10A	24V 1A 220V 0.1	10A	gLgG 10A
HK4-11	24V 2A 230V 0.5A	24V 2.5A 60V 2.5A 230V 2.5A	24V 1A 48V 0.3A 60V 0.15A	2.5A	gLgG 10A

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010307099875

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

Siemens AG, I IA CE
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

NAME AND ADDRESS OF THE FACTORY

Siemens AG, I IA CE
Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit Breaker
MS450, MS451, M0450: see appendix for details

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.2-2008, GB14048.4-2003

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Aug. 16, 2011 Date of expiry: Mar. 22, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec. 12, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0433853