



中国国家强制性产品认证证书

证书编号: 2011010304454200

委托人名称、地址

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

生产者(制造商)名称、地址

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

生产企业名称、地址

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

产品名称和系列、规格、型号

接触器

GA75, GAE75 (型号解释详见附件); Ith=125A; DC-
1:Ue/Ie:DC220V/120A, DC440V/100A, DC660V/75A; DC-
3:Ue/Ie:DC220V/100A, DC440V/85A; DC-5:Ue/Ie:DC220V/85A, DC440V/35A;
Us:AC200-240V 50Hz, AC24V 50Hz/60Hz, AC110V 50Hz/AC110V-120V
60Hz, DC24V, DC220V, DC110V, DC250V; 3P

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2011年10月12日 有效期至: 2016年01月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2011年01月10日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0463968



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2011010304454200

纸号: 463968

型号的解释:

GAE	75	-	I	0
I	II		III	IV

I - Main designation

GA / GAE

II - Range size

75A

III - Main Pole Construction; number of NO main poles

IV - Main Pole Construction; number of NC main poles

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010304454200

NAME AND ADDRESS OF THE APPLICANT

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME AND ADDRESS OF THE FACTORY

ABB France Low Voltage Products Division
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME, MODEL AND SPECIFICATION

Contactor

GA75, GAE75; I_{th}=125A; DC-1:U_e/I_e:DC220V/120A, DC440V/100A, DC660V/75A; DC-3:U_e/I_e:DC220V/100A, DC440V/85A; DC-5:U_e/I_e:DC220V/85A, DC440V/35A;
Us:AC200-240V 50Hz, AC24V 50Hz/60Hz, AC110V 50Hz/AC110V-120V 60Hz, DC24V, DC220V, DC110V, DC250V; 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Oct.12,2011 Date of expiry: Jan.10,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jan.10,2011

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 0463968