



中国国家强制性产品认证证书

证书编号: 2009010304352748

申请人名称及地址

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

商标: ABB

制造商名称及地址

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

生产企业名称及地址

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

产品名称和系列、规格、型号

交流接触器

EH800 Ue:1000V;Ie:1000A;使用类别:AC-1;Ith:1000A; Us:220-230V 50Hz, 230V-240V 60Hz; 配用辅助触头: CAL16-11A, CAL16-11B, CAL16-11C, CAL16-11D; AC-15:Ue/Ie:24-127V/220-240V/6A, 380-440V/4A, 500-690V/1A; DC-13:Ue/Ie:24V/48V/6A, 72V/4A, 125V/1.8A, 250V/0.6A

产品标准和技术要求

GB 14048.4-2003

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2009年07月07日

本证书的有效性依据发证机构的定期监督获得保持。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0119862



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010304352748

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

NAME, MODEL AND SPECIFICATION

Contactor

EH800 Ue:1000V;Ie:1000A;使用类别:AC-1;Ith:1000A; Us:220-230V 50Hz, 230V-240V 60Hz; 配用辅助触头: CAL16-11A, CAL16-11B, CAL16-11C, CAL16-11D; AC-15:Ue/Ie:24-127V/220-240V/6A, 380-440V/4A, 500-690V/1A; DC-13:Ue/Ie:24V/48V/6A, 72V/4A, 125V/1.8A, 250V/0.6A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jul. 07, 2009

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0119862