



中国国家强制性产品认证证书

证书编号: 2011010309459316

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg 德国

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg 德国

生产企业名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg 德国

产品名称和系列、规格、型号

热过载继电器

T16(型号规格见附件)

产品标准和技术要求

GB 14048.4-2003

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2011年02月10日 有效期至: 2016年02月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0369221



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2011010309459316

纸号: 369221

T16

Ue: AC690V

Ie: 0.1-0.13A, 0.13-0.17A, 0.17-0.23A, 0.23-0.31A, 0.31-0.41A, 0.41-0.55A, 0.55-0.74A, 0.74-1A, 1-1.3A,

1.3-1.7A, 1.7-2.3A, 2.3-3.1A, 3.1-4.2A, 4.2-5.7A, 5.7-7.6A, 7.6-10A, 10-13A, 13-16A

脱扣级别: 10; 极数: 3P

配用的辅助触头(本体):

NC(95/96):

AC-15: Ue/Ie: 120V/240V/3A, 380V/0.95A, 500V/0.75A, 600V/0.6A;

DC-13: Ue/Ie: 24V/1.25A, 60V/1.25A, 125V/0.55A, 250V/0.27A, 500V/0.15A, 600V/0.1A;

NO(97/98):

AC-15: Ue/Ie: 120V/240V/380V/500V/0.75A

DC-13: Ue/Ie: 24V/1.25A, 60V/1.25A, 125V/0.55A, 250V/0.27A, 500V/0.15A, 600V/0.1A;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010309459316

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

T16(Model and specification see the appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2003

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb.10, 2011 Date of expiry: Feb.10, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0369221