



IEC SYSTEM FOR CONFORMITY TESTING TO
STANDARDS FOR SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-6649/1

CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.
Registration date: 2004-09-20
Product: Motor starter / Circuit-breakers

Applicant: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Manufacturer: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Factory: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
nb: Additional factory information on page 2 69123 HEIDELBERG

Rating and principal characteristics: In 0,1 A-0,16 A.....20 A - 25 A; Ue 690 Vac with Ics=Icu=max 100 kA; utilization category AC3; magnetic trip 15 times In;

Trade mark (if any): ABB

Model/Type reference: MS325 and MO325

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-2(ed.2);am1
60947-4-1(ed.1);am1;am2

Test Report Ref. No: 2024903.52, 2024903.53, 2024903.54

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H. R. M. Barends

Date of issue: 2004-09-20



IEC SYSTEM FOR CONFORMITY TESTING TO
STANDARDS FOR SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-6649/1

ABB Elsysynn Herspicka 13 61900 BRNO Czech Republic	
Additional information (if necessary)	
This CB Test Certificate is issued by the National Certification Body	
KEMA Quality B.V. Utrechtseweg 310 P.O. Box 5185 6802 ED Arnhem The Netherlands	
Signed by: H. R. M. Barends	
Date of issue: 2004-09-20	