

OFFICE OF **FAIR TRADING**

NSW Consumer Protection Agency
Department of Commerce

Certificate Number: 20676

CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY SAFETY ACT 1945

ISSUED TO:

ABB Australia Pty Ltd

CLASS OF ARTICLE:

Miniature Overcurrent Circuit Breaker

DESCRIPTION OF ARTICLE:

Miniature Overcurrent Circuit Breakers

[1, 1+N, 2, 3, 3+N and 4 Pole Miniature Overcurrent Circuit Breakers]

Trade Name: 'ABB'

Rated Voltage : 240/415V, ac

Rated Continuous Currents: 6A - 63A

Instantaneous Tripping Characteristics: Type 'B' and 'C'

Interrupting Capacity (Icn) : 6000A

EXAMINED FOR COMPLIANCE WITH: AS/NZS 60898.1 : 2004

TYPE REFERENCE CODE: Series S200 (S201, 202, 203, 204)


APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number
NSW20676

DATE OF APPROVAL: 18 April 2005

This approval expires 18 April 2010 unless suspended, cancelled, renewed or extended.

for Commissioner of Fair Trading



OFFICE OF FAIR TRADING

NSW Consumer Protection Agency
Department of Commerce

ADDENDUM TO CERTIFICATE OF APPROVAL No 20676

Particulars of Modification(s)

1. Series S200M (S201M, S201M, S203M, S204M) being similar to the original S200 Series (S201, S202, S203, S204) except for an Interrupting Capacity (Icn) of 10,000A in lieu of 6000A.

2. Series S200P Series (S201P, S202P, S203P, S204P) being similar to original S200 Series (S201, S2102, S203, S204) except as follows:-
 - (a) **Rated Continuous Currents: 0.5A - 63A**
Instantaneous Tripping Characteristics:-
Type 'B': 6A; 10A - 63A.
Type 'C': 0.5A - 63A.
Type 'D' 0.5A - 25A.

 - (b) **Rated Interrupting Capacity (Icn):**
0.5A - 25A : 25,000A
32A - 63A : 15,000A

Approved: 18 April 2005

for Commissioner

Mr Ian Richardson
ABB Australia Pty Ltd
PO Box 4294
MOUNT WAVERLEY VIC 3149

File Ref: NSW20676
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 0735

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20676

Miniature Overcurrent Circuit Breaker

Please find enclosed an addendum to the certificate as sought in your application.

Approved articles may now be marked with either-

- (a) the mark (or marks) as shown on the Certificate; or
- (b) the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

THE APPROVAL NOW EXPIRES ON 18/04/2015 unless it is renewed, extended, suspended or cancelled.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,



for Deputy Commissioner, Fair Trading Operations
24 March 2010

Ref: NSW20676

RENEWAL OF CERTIFICATE OF APPROVAL NSW20676

PARTICULARS OF RENEWAL

The Approval of Miniature Overcurrent Circuit Breaker Series S200 (S201, 202, 203, 204) and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 18/04/2015 unless it is renewed, extended, suspended or cancelled.



for Deputy Commissioner, Fair Trading Operations