



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010304138318

NAME AND ADDRESS OF THE APPLICANT

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME AND ADDRESS OF THE FACTORY

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME, MODEL AND SPECIFICATION

Contacteur

UA50-30... RA Ue: ≤690V Ith:100A Ie:66A(40°C) 使用类别:AC-6b 极数:3P 额定绝缘电压:1000V
额定限制短路电流:25kA; UA63-30... RA Ue: ≤690V Ith:125A Ie:76A(40°C) 使用类别:AC-6b 极
数:3P 额定绝缘电压:1000V 额定限制短路电流:25kA; UA75-30... RA Ue: ≤690V Ith:125A Ie:88A
(40°C) 使用类别:AC-6b 极数:3P 额定绝缘电压:1000V 额定限制短路电流:25kA

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED
FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY
CERTIFICATION

ISSUED DATE: Dec. 28, 2004

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY
THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0174885