



DESCRIPTIVE AND TEST REPORT

Montréal ■ Toronto ■ Edmonton ■ Vancouver ■ Japon ■ Hong Kong ■ Singapour
Montréal ■ Toronto ■ Edmonton ■ Vancouver ■ Japan ■ Hong Kong ■ Singapore

REPORT NO: LR 23701-102

- Edition 1:** May 31, 1995; Application No LR 23701-102 - Eastern Region
Issued by M. Therrien, Tech.; Reviewed by J.P. Boivin, Eng.
- Edition 2:** March 8, 1996; Application No LR 23701-107 - Eastern Region
Issued by J.-P. Boivin, Eng.
- Edition 3:** July 10, 1996; Application No LR 23701-109 - Eastern Region
Issued by G. Foulem, E.I.T.; Reviewed by J.-P. Boivin, Eng.

Certificate of Compliance has been issued.

Pages Replaced: 1, 2, 3, 8 and 11
Pages Added: 8.1 and 8.2
Annexe Added: "A" (Pages 30 to 31)
Photograph Added: 7
Annexe Added: "T" (page 40)

Contents: Pages - 1 to 11
Photographs - 1 to 7
Appendix A - 31 pages
Appendix T - 40 pages (In principal file only)

SUBJECT

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies
CLASS 6228 81 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal Block, ADO Series.

<u>Type</u>	<u>Voltage Group (V)</u>	<u>Current Rating (A)</u>	<u>Wire Range (AWG)</u>
D1, 5/6 ADO	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.ADO.1	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.ADO.2	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.ADO.4	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.ADO.C	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.N.ADO	600 B, C, D, E	18	1 to 3 No 22-16
D1,5/6.P1.ADO	600 B, C, D, E	-	1 to 3 No 22-16
D1,5/6.P.ADO	600 B, C, D, E	-	1 to 3 No 22-16
D1,5/6.SNT2...ADO	600 B, C, D, E	15	1 to 3 No 22-16
D1,5/6.S.ADO	600 B, C, D, E	10	1 to 3 No 22-16
D1,5/8.SFT.ADO	600 B, C, D, E	10A	1 to 3 No 22-16
D1,5/8.SF...T.ADO	600 B, C, D, E	10A	1 to 3 No 22-16
D1,5/8.SNNT.ADO	600 B, C, D, E	10A	1 to 3 No 22-16
D2,5/8 ADO	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.ADO.1	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.ADO.2	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.ADO.4	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.ADO.C	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.N.ADO	600 B, C, D, E	25	1 to 3 No 16-14
D2,5/8.P1.ADO	600 B, C, D, E	-	1 to 3 No 16-14
D2,5/8.P.ADO	600 B, C, D, E	-	1 to 3 No 16-14

REPLACES

Page No: 2

Page Date: March 8, 1996

Application No: LR 23701-107

REPORT NO: LR 23701-102

Page No: 2

Date Issued: July 10, 1996

Application No: LR 23701-109

Reviewed By: J.-P. Boivin, Eng.

Issued By: G. Foulem, E.I.T.

<u>Type</u>	<u>Voltage Group (V)</u>	<u>Current Rating (A)</u>	<u>Wire Range (AWG)</u>
D2,5/8.SNT2...ADO	600 B, C, D, E	15	1 to 3 No 16-14
D2,5/8.SFT.ADO2	600 B, C, D, E	10A	1 to 3 No 16-14
D2,5/8.SF...T.ADO2	600 B, C, D, E	10A	1 to 3 No 16-14
D2,5/8.S.ADO	600 B, C, D, E	15	1 to 3 No 16-14
D4/6.ADO.T2	600 B, C, D, E	18	ADO: 1 to 3 No 22-16 SCREW: 1 No 10-12 2 No 14 2 or 3 No 16 1 or 2 No 18 1 to 3 No 20-22
D4/6,ADO	600 B, C, D, E	18	"
D4/6.ADO.1	600 B, C, D, E	18	"
D4/6.ADO.2	600 B, C, D, E	18	"
D4/6.ADO.4	600 B, C, D, E	18	"
D4/6.ADO.C	600 B, C, D, E	18	"
D4/6 D2.ADO	600 B, C, D, E	18	"
D4/6 D2.ADO.1	600 B, C, D, E	18	"
D4/6.N.ADO	600 B, C, D, E	18	"
D4/6.P1.ADO	600 B, C, D, E	-	"
D4/6.P.ADO	600 B, C, D, E	-	"
D4/6.5	600 B, C, D, E	15	"
D4/6.SN.ADO	600 B, C, D, E	15	"
D4/6.SNT2...ADO	600 B, C, D, E	15	"
D4/8.S ADO	600 B, C, D, E	15	"
D4/8.SN.ADO	600 B, C, D, E	15	"
D4/8.SNT...ADO	600 B, C, D, E	15	"
D4/8.SF.ADO	600 B, C, D, E	10	"
D4/8.SFT2.ADO	600 B, C, D, E	10	"
D4/8.SF...ADO	600 B, C, D, E	10	"
D4/8.SF...T2.ADO			
D4/8.SNN.ADO	600 B, C, D, E	10	"
D4/8.SNNT2.ADO	600 B, C, D, E	10	"
D4/8.SF.ADO2	600 B, C, D, E	10	"
D4/8.SFT2.ADO2	600 B, C, D, E	10	"
D4/8.SF...ADO2	600 B, C, D, E	10	"
D4/8.SF...T2.ADO2	600 B, C, D, E	10	"
D4/8.SNN.ADO2	600 B, C, D, E	10	"
D4/8.SNNT2.ADO2	600 B, C, D, E	10	"

REPLACES

Page No: 3
Page Date: March 8, 1996
Application No: LR 23701-107

REPORT NO: LR 23701-102
Page No: 3
Date Issued: July 10, 1996
Application No: LR 23701-109

Reviewed By: J.-P. Boivin, Eng.

Issued By: G. Foulem, E.I.T.

D6/8.ADO.1	600 B, C, D, E	25	ADO: 1 to 3 No 16-14 SCREW: 1 No 8-12 1-2 No 14-16 1 to 3 No 18-22 2 No 12 str
D6/8.ADO.2	600 B, C, D, E	25	"
D6/8.ADO.4	600 B, C, D, E	25	"
D6/8.ADO.C	600 B, C, D, E	25	"
D6/8.N.ADO	600 B, C, D, E	25	"
D6/8.P1.ADO	600 B, C, D, E	-	"
D6/8.P.ADO	600 B, C, D, E	-	"
D6/8.ADO	600 B, C, D, E	25	"

Notes:

1. Terminal blocks specified for group designation D shall be used only in or with industrial control equipment where the load or any single circuit of the terminal block does not exceed 15A at 51-150V, 10A at 151-300V, 5A at 301-600V, or the maximum current rating, whichever is less.
2. Disconnect and fused terminal blocks are shipped with adhesive labels "CAUTION: DO NOT OPERATE WHEN ANY PART IS ALIVE" and "DEBRANCHER L'ALIMENTATION AVANT D'OUVRIR" or equivalent.
3. Suffixes may be added to the catalogue numbers, corresponding to the above terminal blocks, to denote colour (ie. Suffixes .3, .7, .8 etc.).
4. These terminal blocks are Certified only for supply to manufacturers, as components, for the assembly of Certified electrical equipment where the suitability of the combination is determined by the Canadian Standards Association.