



中国国家强制性产品认证证书

证书编号: 2008010302274946

委托人名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

生产者(制造商)名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

生产企业名称、地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

产品名称和系列、规格、型号

隔离开关熔断器组

OS630D, OS800D, OS630B, OS800B, OS630DS, OS800DS; 具体型号解释见附件

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2011年04月02日 有效期至: 2016年04月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008年05月07日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0377669



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2008010302274946

纸号: 377669

OS630D, OS800D, OS630B, OS800B, OS630DS, OS800DS

主要参数:

额定绝缘电压(U_i): 1000V;

额定发热电流(I_{th}):

630A(OS630D, OS630B, OS630DS), 800A(OS800B, OS800D, OS800DS);

额定工作电压(U_e): 3P, 4P: 415V/500V/690V; 2P: 500V/690V;

额定工作电流(I_e):

630A(OS630D, OS630B, OS630DS), 800A(OS800B, OS800D, OS800DS);

额定限制短路电流(I_q): 2P: 80kA(690V), 100kA(500V);

3P: 80kA(415V), 100kA(500V, 690V);

4P: 50kA(690V), 80kA(415V), 100kA(500V, 690V);

使用类别: OS630B, OS630D, OS630DS: AC-21A, AC-22A, AC-23A(2P, 3P);

AC-21B, AC-22B, AC-23B(4P);

OS800B, OS800D, OS800DS: AC-21A, AC-22A, AC-23A;

极数: 2P, 3P, 4P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010302274946

NAME AND ADDRESS OF THE APPLICANT

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

NAME AND ADDRESS OF THE MANUFACTURER

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

NAME AND ADDRESS OF THE FACTORY

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

NAME, MODEL AND SPECIFICATION

Switch-disconnector-fuse

OS630D, OS800D, OS630B, OS800B, OS630DS, OS800DS; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Apr. 02, 2011 Date of expiry: Apr. 02, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: May. 07, 2008

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

Q 0377669