

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕПУБЛИКА

Pod lísem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1041332

**Product:** Circuit-breakers for overcurrent protection for household

**Type:** SH 200, SH200T, SH 200L

**Rating:** AC 230/400 V, AC 230 V, AC 400 V  
SH 200 - "C"/0,5 A-40 A/6 kA; 1, 1+N, 2, 3, 3+N, 4 pól.  
SH 200 - "B"/6 A; 10 A-40 A/6 kA; 1 a 4 pól.  
SH 200L - "C"/40 A/4,5 kA; 1 pól.  
SH 200T - "C"/40 A/3 kA; 1 pól.

**Ordering firm:** ABB-Stotz-Kontakt GmbH  
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

**Manufacturer:** ABB-Stotz-Kontakt GmbH  
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

**Trade mark:**

The test results are stated in the test-report No.: 403690-01/01 of: 03.11.2004

A sample of the product was found to be in conformity with:  
EN 60898-1:2003, ČSN EN 60898-1:2003

The validity of the certificate is limited to: 30.11.2007

11.11.2004

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



403690-01