



# 中国国家强制性产品认证证书

证书编号: 2009010304365509

## 委托人名称、地址

ABB AB, Cewe-Control  
SE-721 61 Vasteras, Sweden

## 生产者(制造商)名称、地址

ABB AB, Cewe-Control  
SE-721 61 Vasteras, Sweden

## 生产企业名称、地址

ABB新会低压开关有限公司  
广东省江门市新会区今古洲工业开发区

## 产品名称和系列、规格、型号

### 辅助触头

CAL18-11, CAL18-11B AC-  
15:Ue/Ie:127V/6A, 230/240V/4A, 400/440V/3A, 500/690V/2A; DC-  
13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A; Ith:16A

## 产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2009年09月18日

有效期至: 2014年09月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0101730



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010304365509

## NAME AND ADDRESS OF THE APPLICANT

ABB AB, Cewe-Control  
SE-721 61 Vasteras, Sweden

## NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Cewe-Control  
SE-721 61 Vasteras, Sweden

## NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen  
City, Guangdong Province

## NAME, MODEL AND SPECIFICATION

Auxiliary contact block

CAL18-11, CAL18-11B AC-  
15:Ue/Ie:127V/6A, 230/240V/4A, 400/440V/3A, 500/690V/2A; DC-  
13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A; Ith:16A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Sep. 18, 2009      Date of expiry: Sep. 18, 2014

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0101730