



中国国家强制性产品认证证书

证书编号: 2008010302274955

申请人名称及地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

商标: ABB

制造商名称及地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

生产企业名称及地址

ABB Oy, Low Voltage Products
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

产品名称和系列、规格、型号

隔离开关

见附件

产品标准和技术要求

GB14048.3-2002

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2008年05月12日

本证书的有效性依据发证机构的定期监督获得保持。



主任:

李怀林

中国质量认证中心

中国·北京·南四环西路188号9区 100070
网址: www.cqc.com.cn



A 0435504



中国国家强制性产品认证证书

附录:

共 1 页, 第 1 页

证书编号: 2008010302274955

纸号: 435504

OT1000E, OT1000X, OT1250E, OT1250X, OT1600E, OT800U, OT1200U, OT1600X

OT1000E:Ith: 1000A; Ue/Ie: 690V/1000A (AC-21A);500V/1000A, 690V/800A (AC-22A);500V/800A, 690V/650A(AC-23A);使用类别: AC-21A, AC-22A, AC-23A;极数: 3P, 4P;

OT1000X:Ue: AC690V;Ith: 1000A;Ie: 1000A;使用类别: AC-21A, AC-22A, AC-23A;极数: 3P, 4P;

OT1250E:Ith: 1250A;Ue/Ie: 690V/1250A (AC-21A),500V/1250A, 690V/1000A (AC-22A),500V/1000A, 690V/650A(AC-23A);使用类别: AC-21A, AC-22A, AC-23A;极数: 3P, 4P

OT1250X:Ue: AC690V,Ith: 1250A,Ie: 1250A;使用类别: AC-21A, AC-22A, AC-23A;极数: 3P, 4P;

OT1600E:Ith: 1600A,Ue/Ie: 690V/1600A (AC-21A) ,500V/1600A, 690V/1250A (AC-22A),500V/1000A, 690V/650A(AC-23A);使用类别: AC-21A, AC-22A, AC-23A;极数: 3P, 4P

OT800U, OT1200U, OT1600X

Ue: AC690V

Ith: 1600A

Ie: 1600A(AC-21A, AC-22A), 1250A(AC-23A)

使用类别: AC-21A, AC-22A, AC-23A

极数: 3P, 4P

注: 此附录与证书同时使用时有效。



主任:

李怀林

中国质量认证中心

中国·北京·南四环西路188号9区 100070

网址: www.cqc.com.cn





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010302274955

NAME AND ADDRESS OF THE APPLICANT

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA, Finland

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA, Finland

NAME AND ADDRESS OF THE FACTORY

ABB Oy, Low Voltage Products
Muottitie 2A, P.O. Box 622, FIN-65101 VAASA, Finland

NAME, MODEL AND SPECIFICATION

Switch-disconnector

see appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.3-2002

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: May. 12, 2008

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

李怀林

Li Huailin

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nanshuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



A 0435504



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

Appendix:

Page 1 of 1

No.: 2008010302274955

Paper: 435504

OT1000E, OT1000X, OT1250E, OT1250X, OT1600E, OT800U, OT1200U, OT1600X

OT1000E:Ith: 1000A; Ue/Ie: 690V/1000A (AC-21A);500V/1000A, 690V/800A (AC-22A);500V/800A, 690V/650A(AC-23A);Utilization category:AC-21A, AC-22A, AC-23A;Poles: 3P, 4P;

OT1000X:Ue: AC690V;Ith: 1000A;Ie: 1000A;Utilization category: AC-21A, AC-22A, AC-23A;Poles: 3P, 4P;

OT1250E:Ith: 1250A;Ue/Ie: 690V/1250A (AC-21A),500V/1250A, 690V/1000A (AC-22A),500V/1000A, 690V/650A(AC-23A);Utilization category: AC-21A, AC-22A, AC-23A;Poles: 3P, 4P

OT1250X:Ue: AC690V,Ith: 1250A,Ie: 1250A;Utilization category: AC-21A, AC-22A, AC-23A;Poles: 3P, 4P;

OT1600E:Ith: 1600A,Ue/Ie: 690V/1600A (AC-21A) ,500V/1600A, 690V/1250A (AC-22A),500V/1000A, 690V/650A(AC-23A);Utilization category: AC-21A, AC-22A, AC-23A;Poles: 3P, 4P

OT800U, OT1200U, OT1600X

Ue: AC690V

Ith: 1600A

Ie: 1600A(AC-21A, AC-22A), 1250A(AC-23A)

Utilization category: AC-21A, AC-22A, AC-23A

Poles: 3P, 4P

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



President:

李怀林



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>