



中国国家强制性产品认证证书

证书编号: 2002010304008904

申请人名称及地址

ABB(香港)有限公司
香港新界大埔墟大埔工业村大喜街3号

商标: ABB

制造商名称及地址

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

生产企业名称及地址

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

产品名称和系列、规格、型号

交流接触器

A95, A110; A95: Ith=145A; AC-3; Ue: AC220/230/240/380/400/415V
Ie=96A, Ue: 440/500/660/690V Ie=30A; A110: Ith=160A; AC-3; Ue: AC220/230/240/380/400/415V Ie=110A, Ue: 440/500/660/690V
Ie=82A, Ue=AC1000 Ie=30A; Es: AC220/230V 50Hz; 3P

产品标准和技术要求

GB14048.4-2003

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2008年06月10日

本证书的有效性依据发证机构的定期监督获得保持。

(本证书为变更证书, 证书首次颁发日期: 2002年07月25日)



主任:

李怀林

中国质量认证中心

中国·北京·南四环西路188号9区 100070

网址: www.cqc.com.cn



A 0457466



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2002010304008904

NAME AND ADDRESS OF THE APPLICANT

ABB (Hong Kong) Ltd.
3 Dai Hei Street Tai Po Industrial Estate Tai Po, Hong Kong

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Cewe-Control
SE-721 61 Vasteras, Sweden

NAME, MODEL AND SPECIFICATION

AC Contactor

A95, A110: A95: Ith 145A; AC-3; Ue: AC220/230/240/380/400/415V
Ie=96A, Ue: 440/500/660/690V Ie=30A; A110: Ith=160A; AC-
3; Ue: AC220/230/240/380/400/415V Ie=110A, Ue: 440/500/660/690V
Ie=82A, Ue=AC1000 Ie=30A; Us: AC220/230V 50Hz, 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jun. 10, 2008

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Jul.25,2002)



President:

李怀林

Li Huailin

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

