



# 中国国家强制性产品认证证书

证书编号: 2008010302274955

### 委托人名称, 地址

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, 芬兰

### 生产者(制造商)名称, 地址

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, 芬兰

### 生产企业名称, 地址

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, 芬兰

### 产品名称和系列、规格、型号

#### 隔离开关

OT1000E, OT1250E, OT1600E, OT800U and OT1200U; Ui:1000V; Ith:1000A  
(OT1000E), 1250A (OT1250E), 1600A (OT1600E, OT800U, OT1200U); Ue:690V; Ie:AC-  
23A: 1000A (OT1000E), 1250A (OT1250E, OT1600E, OT800U, OT1200U); AC-21A, AC-22A:  
1000A (OT1000E), 1250A (OT1250E), 1600A (OT1600E, OT800U, OT1200U); Iew:50kA 1s;  
使用类别: AC-21A, AC-22A, AC-23A; 3P, 4P

### 产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2011年02月10日      有效期至: 2016年02月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008年05月12日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0369232



# 中国国家强制性产品认证证书

附录:


证书编号: 2008010302274955

第 1 页 共 1 页

纸号: 369232

型号的解释:

OT1600 E 12 H P



注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010302274955

## NAME AND ADDRESS OF THE APPLICANT

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

## NAME AND ADDRESS OF THE MANUFACTURER

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

## NAME AND ADDRESS OF THE FACTORY

ABB Oy, Low Voltage Switches  
Muottitie 2A, P. O. Box 622, FIN-65101 VAASA, Finland

## NAME, MODEL AND SPECIFICATION

Switch-disconnector

OT1000E, OT1250E, OT1600E, OT800U and OT1200U; Ui:1000V; Ith:1000A  
(OT1000E), 1250A (OT1250E), 1600A (OT1600E, OT800U, OT1200U); Ue:690V; Ie:AC-  
23A: 1000A (OT1000E), 1250A (OT1250E, OT1600E, OT800U, OT1200U); AC-21A, AC-22A:  
1000A (OT1000E), 1250A (OT1250E), 1600A (OT1600E, OT800U, OT1200U); Icw:50kA 1s;  
Category:AC-21A, AC-22A, AC-23A;3P, 4P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb.10,2011      Date of expiry: Feb.10,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: May.12,2008

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 0369232