



中国国家强制性产品认证证书

证书编号: 2008010309315636

申请人名称及地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

商标: ABB

制造商名称及地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、规格、型号

电子式过载继电器

E200DU, E320DU E200DU:Ue:AC1000V, Ie:60-200A; E320DU:Ue:AC1000V, Ie:100-320A;
脱扣级别:10E, 20E, 30E;极数:3P; 配用辅助触头(本体): Ue/Ie:AC-15:24-
240V/3A, 380-400V/1.1A, 500V/0.72A; Ue/Ie:DC-
13:24V/1.5A, 125V/0.55A, 250V/0.27A

产品标准和技术要求

GB14048.4-2003

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2008年12月25日

本证书的有效性依据发证机构的定期监督获得保持。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0052848



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010309315636

NAME AND ADDRESS OF THE APPLICANT

ABB STÖTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB STÖTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB STÖTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME, MODEL AND SPECIFICATION

Electronic Overload Relays

E200DU, E320DU E200DU:Ue:AC1000V, Ie:60-200A; E320DU:Ue:AC1000V, Ie:100-320A;
脱扣级别:10E, 20E, 30E; 极数:3P; 配用辅助触头(本体): Ue/Ie:AC-15:24-
240V/3A, 380-400V/1.1A, 500V/0.72A; Ue/Ie:DC-
13:24V/1.5A, 125V/0.55A, 250V/0.27A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR
THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Dec. 25, 2008

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE
CERTIFICATION BODY AT REGULAR INTERVALS



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

