



Certificate

PROFIBUS Nutzerorganisation e.V. grants to
ABB STOTZ-KONTAKT GmbH
Eppelheimer Str. 82, 69123 Heidelberg, Germany

the Certificate No.: **Z10093** for the PROFINET IO Device:

Model Name: **CI502-PNIO**
Revision: **-; SW/FW: 1.0.0; HW: 1.0**
GSD: **GSDML-V2.1-ABB-S500-CI502-PNIO-20081215.xml**
Identnumber: **0x001A; 0x0017**
DAP: **DIM1, 0x00000001**

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Conformance Class A	RT_Class_1; RTA; LLDP, SNMP, MIB-II
<input checked="" type="checkbox"/> Hardware	Auto_Negotiation; Auto_Polarity; Auto_Crossover

Test Report Number: **itm 1016 PN 01/02, 2008-Dec-16**
Authorized Test Laboratory: **itm, München, Germany**

The tests were executed in accordance with the following documents:

“Test Specifications for PROFINET IO devices, Version 2.19.1 from May 2007”

“Test Cases for PROFINET IO devices, Version 2.19.1.8 from May 2007”

The certificate is granted according to the document “Framework for testing and certification of PROFIBUS and PROFINET products”.


For all products that are placed in circulation by December 15, 2011 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.


(J. Freitag)


(K.-P. Lindner)