

# CENELEC-Zertifizierungs-Abkommen

CENELEC Certification Agreement · CCA · Accord de Certification du CENELEC

## Mitteilung von Prüfergebnissen

Notification of Test Results

CCA/DE1 33308

Erzeugnis <i>Product</i>	Leistungsschalter / Circuit breaker
geprüft im Auftrag von <i>tested by request of</i>	ABB-Stotz-Kontakt GmbH Eppelheimer Strasse 82, 69123 Heidelberg
hergestellt in (Firma und Ort) <i>manufactured at (Name and place)</i>	ABB-Stotz-Kontakt GmbH Eppelheimer Strasse 82, 69123 Heidelberg
Betriebsdaten und wichtige Merkmale <i>Rating and principal characteristics</i>	$U_e$ : AC 230/400 V; $I_e$ : 0,5 A; 0,75 A; 1 A; 1,6 A; 2 A; 3 A; 4 A; 6 A; 8 A; 10 A; 13 A; 16 A; 20 A; 25 A; 32 A; 40 A; 50 A; 63 A
Warenzeichen (falls vorhanden) <i>Trade mark (if any)</i>	ABB
Typenbezeichnung <i>Model/Type ref.</i>	Series S200
Zus. Information (falls erforderlich) <i>Additional information (if necessary)</i>	Characteristic B; D; D; K; Z; $I_{cu}$ : 15 kA $I_{cs}$ : 7,5 kA 1- to 4-poles

Ein Muster dieses Erzeugnisses ist geprüft und als in Übereinstimmung mit der gültigen Norm  
*A sample of the product has been tested and found to be in conformity with the current standard*

(HD/EN und gleichwertige nationale Norm – Nummer und Ausgabe)  
*(HD/EN and equivalent national standard – Number and edition)*

EN 60947-1:2004  
EN 60947-2:2003

befunden worden, wie es aus dem Prüfbericht (Aktenzeichen/Nr. 70000-4402-0008/38480 ) hervorgeht.  
*as shown in the test report (reference no.).*

D-63069 Offenbach am Main, 2006-08-24  
Merianstrasse 28

Bearbeiter/Tel.: FG32/ Hampe / ham-nk, -417  
Aktenzeichen: 70000-4402-0008/38480  
*Internal reference*

**VDE** VERBAND DER ELEKTROTECHNIK  
ELEKTRONIK INFORMATIONSTECHNIK e.V.

**VDE** Prüf- und Zertifizierungsinstitut  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle / Certification

weitere Bedingungen siehe Rückseite  
*further conditions see overleaf*



Testing Station: VDE Testing and Certification Institute

**CB/CCA-TEST REPORT FORM-IEC/EN 60947-2  
LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR  
PART 2: CIRCUIT-BREAKER**

**TECHNICAL CHARACTERISTIC**

<b>Type:</b>	<b>S200</b>
<b>Number of poles:</b>	<b>1; 1+N; 2; 3; 3+N; 4</b>
<b>Rated operational voltage (U<sub>c</sub>):</b>	<b>AC 230/400V (poles 1) AC 230V (poles 1+N) AC 400V (poles 2 to 4)</b>
<b>Maximum operational voltage:</b>	<b>AC 253/440 V</b>
<b>Rated current (I<sub>n</sub>):</b>	<b>B 1A; 2 A; 3 A; 4 A; 6A; 8 A; 10A; 13A; 16A; 20A, 25A; 32A; 40A, 50A; 63<sup>*)</sup>A C/D 0,5A; 1A; 1,6A; 2A; 3A; 4A, 6A; 8A, 10A; 13A; 16A; 20A, 25A; 32A; 40A, 50A, 63<sup>*)</sup>A <sup>*)</sup> only 1; 1+N; 2 –poles. K/Z 0,5A; 0,75A; 1A; 1,6A; 2A; 3A; 4A; 6A; 8A, 10A; 13A; 16A; 20A, 25A; 32A; 40A, 50A, 63<sup>*)</sup>A <sup>*)</sup> only 1; 1+N; 2 –poles.</b>
<b>Utilization category:</b>	<b>A</b>
<b>Instantaneous tripping current:</b>	<b>B; C; D; K; Z</b>
<b>Ambient temperature:</b>	<b>55°C (B/C/D-characteristic) 30°C (K/Z-characteristic)</b>
<b>Rated ultimate short-circuit breaking capacity (I<sub>cu</sub>):</b>	<b>10000 A</b>
<b>Rated service short-circuit breaking capacity (I<sub>cs</sub>):</b>	<b>7500 A</b>
<b>Grid distance:</b>	<b>62,5 mm</b>

---

Type key page: 2  
Test sequence page 2



**Type key**

S20                      
 A    B    C    D

A) Number of poles: 1; 2; 3; 4; / B) Devices with neutral pole: +NA; / C) Characteristic: B; C; D; K; Z; / D) Rated current: 0.5 A to 63 A

**Test sequence**

Type: S200 (Characteristic "D") Test sequence, Circuit-breaker IEC/EN 60947-2

Number of Test report	Characteristic	Rated current (A)	Number of poles	Testsequence					
				I	II	III	IV	V	Annex H
<b>70000-4402-0008/38480</b>									
-1	D	0.5	1	X*	X	X			
-2	D	0.5	1+N		X	X			
-3	D	0.5	2		X	X			
-4	D	0.5	3+N		X	X			
-5	D	40	1	X	X	X			
-6	D	40	1+N		X	X			
-7	D	40	2		X	X			
-8	D	40	3+N	X	X	X			
-9	D	40	4	X					
-10	D	50	1	X	X	X			
-11	D	50	1+N		X	X			
-12	D	50	2		X	X			
-13	D	50	3+N	X	X	X			X
-14	D	50	4	X					X
-15	D	63	1	X	X	X			
-16	D	63	1+N		X	X			
-17	D	63	2	X	X	X			X

**Test sequence Circuit-breaker IEC/EN 60947-2**

Type: S200 (Characteristic „C“)

Number of Test report	Characteristic	Rated current (A)	Number of poles	Testsequence					
				I	II	III	IV	V	Annex H
<b>70000-4402-0008/38480</b>									
-18	C	0,5	1	X*					
-19	C	40	1	X*					
-20	C	50	1	X*					
-21	C	63	1	X*					

\*) only clause 8.3.3.1

Type: S200 (Characteristic „B“)

Number of Test report	Characteristic	Rated current (A)	Number of poles	Testsequence					
				I	II	III	IV	V	Annex H
<b>70000-4402-0008/38480</b>									
-22	B	1	1	X*					
-23	B	40	1	X*					
-24	B	50	1	X*					
-25	B	63	1	X*					

\*) only clause 8.3.3.1

**Type: S200 (Characteristic „K“)**

Number of Test report	Characteristic	Rated current (A)	Number of poles	Testsequence					
				I	II	III	IV	V	Annex H
70000-4402-0008/38480									
-26	K	0,5	1	X	X	X			
-27	K	40	1	X	X	X			
-28	K	50	1						
-29	K	63	1						

\*) only clause 8.3.3.1

**Type: S200M (Characteristic „Z“)**


Number of Test report	Characteristic	Rated current (A)	Number of poles	Testsequence					
				I	II	III	IV	V	Annex H
70000-4402-0008/38480									
-30	Z	0,5	1	X*					
-31	Z	40	1	X*					
-32	Z	50	1	X*					
-33	Z	63	1	X*					

\*) only clause 8.3.3.1




### Characteristic **D**

S 200, S 200M and S 200P MCBs  
 $I_n = 0.5 \dots 63 \text{ A}$






### Characteristic **K** S 200, S 200M and S 200P $I_n = 0.5 \dots 63 \text{ A}$






### Characteristic **Z** S 200, S 200M and S 200P $I_n = 0.5 \dots 63 \text{ A}$






### Characteristic **B** S 200, S 200M and S 200P MCBs $I_n = 6 \dots 63 \text{ A}$



**characteristic C**  
**S 200, S 200M and S 200P MCBs**  
 $I_n = 0.5 \dots 63 \text{ A}$



VDE Testing and Certification Institute

Section FG32

2006-07-26