INTERNATIONAL ELECTROTECHNICAL COMMISSION (IEC)
COMMISSION ELECTROTECHNIQUE INTERNATIONALE (CEI)

Ref. Certif. No.
SE-40138M1

IEC SYSTEM FOR CONFORMITY TESTING AND CERTIFICATION OF ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTÈME CEI D'ESSAIS DE CONFIRMITÉ ET DE CERTIFICATION DES EQUIPMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC

Product *Produit*	Contactor
Name and address of the applicant *Nom et addresse du demandeur*	ABB Entrelec, Division Control 10 rue Ampère, FR-69685 Chassieu Cedex, FRANCE
Name and address of the manufacturer *Nom et addresse du fabricant*	Same as applicant
Name and address of the factory *Nom et addresse du l'usine*	Same as applicant
Rating and principal characteristics *Valeurs nominales et caractéristiques principales*	AC-1: 170 A 500V AC-3: 150 A 380-440V / 130 A 500V
Trade mark (if any) *Marque de fabrique (si elle existe)*	ABB
Model/type Ref. *Ref. de type*	IOR*170 * denotes type of winding
Additional information (if necessary) *Information complémentaire (si nécessaire)*	This certificate replaces SE-40138, dated 1 February 2005. A new certificate has been issued due to additional coil windings and correction of misprinted type reference.
A sample of the product was tested and found to be in conformity with *Un échantillon de ce produit a été essayé et a été considéré conforme à la*	IEC 60947-4-1:2000+A1
as shown in the Test Report Ref. No. which forms part of this certificate *comme indiqué dans le Rapport d'essais numéro de réference qui constitue une partie de ce certificat*	413694-2, 501238-2

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Intertek Semko AB
Stockholm 18 February 2005

BSE/AKL

Intertek ETL SEMKO

Postal address
Intertek Semko AB
P.O. Box 1103
SE-164 22 KISTA

Visiting address
Torshamnsgatan 43
KISTA-STOCKHOLM

Telephone
Int +46 8 750 00 00

Telefax
Int +46 8 750 60 30

04-02 Nockeby Tr. 17822/Mc