



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010304138321

NAME AND ADDRESS OF THE APPLICANT

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME AND ADDRESS OF THE FACTORY

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

NAME, MODEL AND SPECIFICATION

Contactor

TAL30-30, TAL30-30.. RT, TAL40-30, TAL40-30.. RT; TAL30-30, TAL30-30.. RT; Ue: 440V, 500V, 690V, Us=DC17-32V, Ith=65A, Ie: 33A(440V), 28A(500V), 18A(690V) AC-3, 33A(440V), 23A(500V), 15A(690V) AC-4; 使用类别: AC-3, AC-4, 3P; TAL40-30, TAL40-30.. RT; Ue=440V, 500V, 690V; Us=DC17-32V, Ith=65A, Ie: 40A(440V), 33A(500V), 21A(690V) AC-3, 33A(440V), 23A(500V), 18A(690V) AC-4; 使用类别: AC-3, AC-4, 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048. 4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Dec. 28, 2005

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Dec. 28, 2004)



President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0239104



中国国家强制性产品认证证书

证书编号: 2004010304138321

申请人名称及地址

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

商标: ABB

制造商名称及地址

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

生产企业名称及地址

ABB-ENTRELEC Division Control
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

产品名称和系列、规格、型号

接触器

TAL30-30, TAL30-30..RT, TAL40-30, TAL40-30..RT; TAL30-30, TAL30-30..RT: Ue: 440V, 500V, 690V, Us=DC17-32V, Ith=65A, Ie: 33A(440V), 28A(500V), 18A(690V) AC-3, 33A(440V), 23A(500V), 15A(690V) AC-4; 使用类别: AC-3, AC-4; 3P; TAL40-30, TAL40-30..RT: Ue=440V, 500V, 690V; Us=DC17-32V, Ith=65A, Ie: 40A(440V), 33A(500V), 21A(690V) AC-3, 33A(440V), 23A(500V), 18A(690V) AC-4; 使用类别: AC-3, AC-4; 3P

产品标准和技术要求

GB14048.4-2003

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2005年12月28日

本证书的有效性依据发证机构的定期监督获得保持。

(本证书为变更证书, 证书首次颁发日期: 2004年12月28日)



主任:

李怀林



中国·北京·朝阳门外大街甲10号 100020 网址: www.cqc.com.cn

A 0239104