



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010304088235

## NAME AND ADDRESS OF THE APPLICANT

ABB-ENTRELEC Division Control  
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

TRADE MARK: ABB

## NAME AND ADDRESS OF THE MANUFACTURER

ABB-ENTRELEC Division Control  
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

## NAME AND ADDRESS OF THE FACTORY

ABB-ENTRELEC Division Control  
10 rue Ampere Z. I. BP114 69685 Chassieu cedex France

## NAME, MODEL AND SPECIFICATION

Contactor relay

N22E / N31E /N40E AC-15: Ue/Ie: 127V/6A, 240V/4A 440V/3A, 690V/2A DC-13:  
Ue/Ie: 24V/6A, 48V/2.8A 72V/1A, 125V/0.55A 250V/0.3A Ith: 16A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.5-2001

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR  
THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Sep. 30, 2003

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY  
THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

李怀林

Li Huailin

