

**certificate of conformity n° 031-01**  
 english version - original in french



**issued to :** ABB Control  
 10 rue Ampère  
 69680 - CHASSIEU  
 FRANCE

**for the apparatus :** free air three-pole contactor

reference : AE 75-30-00 + 1CAL 5-11  
 manufacturer : ABB Control

**according to standard(s) :** IEC60947-4-1 (1990-05), corrigendum (1991-12), amendment 1 (1994-11) and amendment 2 (1996-08) - EN 60947-4-1 (1992-01) amendment 1 (1995-01) and amendment 2 (1997-06) - NFEN 60947-4-1(1993-02) amendment 1 (1995-04) and amendment 2 (1997-12) test sequence I.

**rated characteristics :**

Operational voltage : Ue (V)	≤ 240	>240 and ≤ 415	>415 and ≤440	>440 and ≤500	>500 and ≤690
Operational current : Ie (A) AC-1	125	125	125	125	125
: Ie (A) AC-3	75	75	70	65	46
: Ie (A) AC-4	75	75	70	65	46

**relevant document(s) :**

record of proving test n° G11 2000578

**conclusion :**

The relevant document(s) enable to state that the apparatus, asserted by the applicant as representing the type referenced, comply with requirement of standards used for rated characteristics presented above.

Fontenay-aux-Roses, on April 10, 2001

The chairman of ASEFA,



HELLER