



Certificate of Compliance

Certificate Number: LR 15332-67

Revision: LR 15332-97

Date Issued: April 14, 1999

Issued to: ABB Schalt-und
Steuerungstechnik Gmbh
Eppelheimer Strasse 82
69123 HEIDELBERG
Germany

The products listed below are eligible to bear the CSA Mark shown



Issued by: Michel Legault, Eng.
Pointe Claire, QC, Canada

Signature:

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Thermal Overload Relays, open type, 600V ac 3-ph, adjustable manual and automatic reset, Types

- T450SU, 40A up to 400A, in 8 setting ranges
- T450DU, 185A up to 400A, in 4 setting ranges
- TA450SU, 40A up to 400A, in 8 setting ranges
- TA450DU, 185A up to 400A, in 4 setting ranges

Notes:

1. The type designation may be completed with numbers indicating the setting range.
2. The overload relays are intended for use with Certified ac contactors or for separate use.
3. The overload relays are provided with control contacts, rating code for NC B600 and for NO C600 (same polarity above 300V).
4. The relays have not been checked under short circuit situations. This has to be established in the final application.
5. The overload relays are Certified as component for use only in other Certified equipment, where the suitability of the combination has been determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-95 - Industrial Control Equipment