

## CERTIFICATE OF COMPLIANCE

**CERTIFICATE NUMBER:** 03112002-E116595  
**ISSUE DATE:** March 11, 2002

**Issued to:** ABB SACE S P A  
VIA BAIONI 35  
24123 BERGAMO, ITALY

**Report Reference:** October 7, 1996


**This is to Certify that representative samples of:** Molded Case Switches Type ISOMAX S4N-D and S4H-D

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.**

**Standard(s) for Safety:** UL 489, Molded-Case Circuit Breakers, Molded-Case Switches, and Circuit Breaker Enclosures

**Additional Information:** These devices are 3 and 4 pole, rated 600 V with current rating of 250 A.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

**LOOK FOR THE UL VERIFICATION MARK ON THE PRODUCT**

**Engineer:**

  
Nicholas Roumbos

**Review Engineer:**

  
Salvatore Porcillo