



# Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 26 417 - 05 HH  
Company ABB France  
10, Rue Ampere  
69685 Chassieu Cedex, FRANCE

Product Description D.C. Operated contactors  
4-poles  
Type AL26-40-xy  
1-pole and 4-pole aux. contacts CA 5-xy

Environmental Category C

Technical Data / Range of Application

Main contacts with screw terminals:	AL26-40-xy
Max. rated voltage Ue:	690 V
Rated frequency limits:	25...400 Hz
Rated insulation voltage Ui:	1000 V
Rated operational current Ie (AC-1 /690 V):	40 A ( 55°C)
Rated operational power (AC-3 /690V):	15 kW
Required fuse protection according to maker's specification	
Add-on auxiliary contacts with screw terminals (1-pole CA 5-xy, 4-pole CA 5-xy):	
Rated insulation voltage:	690 V
Conv. Free-air thermal current Ith:	16 A
Rated operational current Ie (AC-15 690V)	2 A
Rated operational current Ie (DC-13 250V)	0,3 A
Short circuit protection (gG fuse)	10 A

(x=N.O contacts y=N.C. contacts)

Test Standard Guidelines for the Performance of Type Approvals Part 2, Edition 2003; IEC 60947-1 (2001-12) Ed. 3.2; IEC 60947-4-1 (2002-12) Ed. 2.1; IEC 60947-5-1 (2003-11) Ed. 3

Documents Test report 2005391-A; 2005391-1-A; 2005443-A; 2005467-A-M; 2005469-A-M; LCIE FR 3191/60016914-509747; LCIE FR 3192/60016914-509747; LCIE FR 3193/60016914-509747; SEMKO SE-30112; SEMKO SE-30113; SEMKO SE-30114; LCIE FR 60031638

Remarks None

Valid until 2016-12-04

Page 1 of 1


Type Approval Symbol



File No. I.K.03

Hamburg, 2011-12-05

Germanischer Lloyd

  
Christoph Kutzner

  
Harald Amberger

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".