



Certificate of Conformity

LOVAG-Certificate No. FR04-012

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

Apparatus

CONTACTOR

Designation

TAL 12-30-10

Manufacturer or responsible vendor

ABB Entrellec – Control division
10 rue Ampère
69685 – CHASSIEU

Tested for: ABB Entrellec

Tested by: ASEFA platform G11

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-4-1(2nd edition 2000-11) and amend 1 (2002), EN 60947-4-1(2001-02) and amend 1 (2002), NF EN 60947-4-1 (2001-05) and amend 1 (2003) tests sequences I and IV


The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

Main circuit 3 pole $U_i = 1000 \text{ V}$ $U_{imp} = 8 \text{ kV}$ $I_{th} = 28 \text{ A}$

Utilization category	AC1	AC3	AC4
$U_e \leq 500 \text{ V}$	$I_e = 27$	$I_e = 12$	$I_e = 12$
$U_e > 500 \text{ V}$ and $\leq 690 \text{ V}$	$I_e = 27$	$I_e = 9$	$I_e = 9$

This document includes Report No.: G11-2003863
Issue Date: 2004.01.16

Responsible Certification Body


I. HELLER
Authorized Signature
Date: 16 MARS 2004

ASEFA - Avenue du Général Leclerc - 92260 Fontenay-aux-Roses France
Phone : 33 (1) 40.95.60.60 - Fax : 33 (1) 40.95.60.03