

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 03112002-E93565
ISSUE DATE: March 11, 2002

Issued to: ABB SACE S P A
VIA BAIONI 35
24123 BERGAMO, ITALY

Report Reference: April 9, 1998


This is to Certify that representative samples of: Molded case circuit breakers Type ISOMAX S1N

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded-Case Circuit Breakers, Molded-Case Switches, and Circuit Breaker Enclosures

Additional Information: These are three pole 40 degrees C thermal magnetic circuit breakers with noninterchangeable trip units. These circuit breakers are intended to be used in suitable Listed enclosures min 220 high by 123 wide by 72 mm deep. When tripped the handle takes an intermediate position between "Off" and "On".

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL VERIFICATION MARK ON THE PRODUCT

Engineer:


Nicholas Roubos

Review Engineer:


Salvatore Porcillo