



FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

### **V11527-a7cde. TF 02-Ex Foundation Fieldbus Temperature Transmitter**

- ✓ IS / I / 1 / ABCD / T\* - V11527-F-S11; Entity; FISCO
- ✓ I / 0 / AEx ia / IIC / T\* - V11527-F-S11; Entity; FISCO
- ✓ NI / I / 2 / ABCD / T\* - V11527-F-N11; Nonincendive Wiring Parameters

\* Temperature Codes T6 Ta = 50°C; T4 Ta = 85°C

a = Bus System FR, FA  
c = Construction 3, 1, 4, R, P, X  
d = Connections 0, M  
e = Programming 0, 1

#### Entity Parameters:

Supply Circuit Terminals + and -:

Groups A, B: Vmax = 24Vdc, Imax = 360mA, Ci = 5nF, Li = 10µH

Groups C, D: Vmax = 24Vdc, Imax = 380mA, Ci = 5nF, Li = 10µH

Sensor Circuit Terminals 1, 2, 3, 4:

Groups A, B: Voc = 5.5Vdc, Isc = 25mA, Po = 35mW, Ca = 2.6µF, La = 2mH

Groups C, D: Voc = 5.5Vdc, Isc = 25mA, Po = 35mW, Ca = 15µF, La = 2mH

#### Special conditions:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

### **V11526-aScdefg. TF 202-Ex Foundation Fieldbus Temperature Transmitter**

IS / I, II, III / 1 / ABCDEFG / T\* - V11526-F-S11; Entity; FISCO

I / 0 / AEx ia / IIC / T\* - V11526-F-S11; Entity; FISCO

NI / I / 2 / ABCD / T\* - V11526-F-N11; Nonincendive Wiring Parameters

NI / II, III / 2 / FG / T\* - V11526-F-N11; Nonincendive Wiring Parameters

ANI / I / 2 / ABCD / T\* - V11526-F-N21; Nonincendive Wiring Parameters

ANI / II, III / 2 / FG / T\* - V11526-F-N21; Nonincendive Wiring Parameters

Enclosure Type 4X

\* Temperature Codes T6 Ta = 50°C; T4 Ta = 85°C

a = Bus System FR, FA  
c = Display / Construction N  
d = Material A, E  
e = Connections M, D, 1, 2, 3, 4  
f = Mounting Field Housing 1, 2, 3, 4, 5  
g = Programming S, K

**Entity Parameters:**

Supply Circuit Terminals + and -:

Groups A, B:  $V_{max} = 24V_{dc}$ ,  $I_{max} = 360mA$ ,  $C_i = 5nF$ ,  $L_i = 10\mu H$

Groups C, D:  $V_{max} = 24V_{dc}$ ,  $I_{max} = 380mA$ ,  $C_i = 5nF$ ,  $L_i = 10\mu H$

Sensor Circuit Terminals 1, 2, 3, 4:

Groups A, B:  $V_{oc} = 5.5V_{dc}$ ,  $I_{sc} = 25mA$ ,  $P_o = 35mW$ ,  $C_a = 2.6\mu F$ ,  $L_a = 2mH$

Groups C, D:  $V_{oc} = 5.5V_{dc}$ ,  $I_{sc} = 25mA$ ,  $P_o = 35mW$ ,  $C_a = 15\mu F$ ,  $L_a = 2mH$

**Equipment Ratings:**

Intrinsically safe apparatus with intrinsically safe circuits for use in Class I, Division 1 and 2 Groups A, B C and D, Class II, Division 1, Groups E, F and G, Class II, Division 2, Groups F and G Class III and Class I, Zone 0, AEx ia or ib IIC, Hazardous (Classified) Locations, indoor temperature class T6 at an ambient of 50°C, T4 at an ambient of 85°C

**Approved for:**

ABB Automation Products GmbH  
Borigstrasse 2, D-6375, Aizenau  
Germany