






1 2 3 4 5 6



|    |  |
|----|--|
| 1  | D-BEARING 6326M/C3<br>NU326M/C3 (OPTIONAL)   |
| 2  | N-BEARING 6322/C3<br>INSULATED 6322/C3 (OPTIONAL)                                    |
| 3  | TERMINAL BOX FOR CONTROL<br>CAPLE 10-14, 2xM20x1,5<br>LARGER TERMINAL BOX (OPTIONAL) |
| 4  | SPM NIPPLE DE AND NDE  |
| 5  | PT-100 FOR BEARINGS (OPTIONAL)   |
| 6  | INTERMEDIATE BOX   |
| 7  | FREE DISTANCE FOR COOLING  |
| 8  | TERMINAL BOX FOR HEATING ELEMENT<br>CAPLE 10-14, 1xM20x1,5 (OPTIONAL)                |
| 9  | GREASING NIPPLE DE AND NDE   |
| 10 | EARTHING, M12, FOR M3GM MAX 150mm <sup>2</sup>                                       |
| 11 | TRANSPORTATION COVER,<br>SIX (6) LEADS OUT 1.5m (5ft)                                |



BEFORE COMMISSIONING, TERMINAL ARRANGEMENT SHALL BE SUCH THAT THE STATOR CONNECTION CABLES ARE COVERED WITH EARTHED PROTECTIVE STRUCTURE (E.G. MAIN TERMINAL BOX AND ADEQUATE INTERMEDIATE BOX).

MAIN TERMINAL BOXES ARE NOT INCLUDED IN MOTOR MANUFACTURER'S DELIVERY.

MAIN TERMINAL BOXES MUST FILL FOLLOWING REQUIREMENTS:

- FOR EXPLOSIVE ENVIRONMENTS EX CERTIFIED
- ENCLOSURE IP55 OR HIGHER ACC. TO SITE CONDITIONS

MAXIMUM MASS FOR MTB ASSEMBLY 600 kg,  
MAXIMUM MOMENT FROM MTB ASSEMBLY ACCORDING TO POINT W 1600Nm.

DIMENSIONS IN INCHES

DURING THE INITIAL INSTALLATION PLACE 0.0787" SHIMS UNDER THE FEET OF THE MOTOR. THE CUSTOMER IS RESPONSIBLE FOR THE DESIGN AND CONSTRUCTION OF THE FOUNDATION. IT SHALL BE SUFFICIENTLY RIGID TO WITHSTAND SHORT CIRCUIT FORCES. TO AVOID RESONANCE VIBRATIONS THE FOUNDATION SHALL BE DESIGNED SO THAT THE NATURAL FREQUENCY OF FOUNDATION TOGETHER WITH MACHINE IS NOT WITHIN ±20% OF RUNNING SPEED FREQUENCY. THE CUSTOMER IS ALSO RESPONSIBLE FOR LATERAL AND TORSIONAL CRITICAL SPEED ANALYSIS OF THE COMPLETE INSTALLATION.

| Rev                                   | Change                 | Date              | Prep.    | Approved              | Scale    |
|---------------------------------------|------------------------|-------------------|----------|-----------------------|----------|
| Prepared                              | 2006-09-18 M.VÄKIPARTA | Responsible dept. | ATAP/PID | Title                 | 1:20     |
| Approved                              | 2006-09-18 O.LAHTINEN  | Take over dept.   |          | SQUIRREL CAGE MOTOR   |          |
| Material                              |                        | Code              |          | 13 BM 72_NEMA A / 450 | Language |
| Supersedes                            | Superseded by          | Type              |          | M3BM/GM 728L4-12 B3   | Size     |
| ABB                                   |                        | Document No.      | Revision | 3GZF500002-13         | Sheet    |
| ABB Oy, Electrical Machines, Helsinki |                        |                   | A        |                       | 1/1      |

1 2 3 4 5 6

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © ABB Oy, Electrical Machines, Helsinki

General tolerances ISO 2768-mK  
Threads according to ISO 965 tolerance class 6H  
Symbols for roughness acc. to ISO 1302

A

B

C

D