

Preventive maintenance for ABB industrial drives, ACS800

ABB recommends regular preventive maintenance of AC drives throughout their lifetime to ensure maximum availability, minimum unplanned repair costs, optimized performance and extended lifetime.

Drive preventive maintenance consists of annual drive inspections and component replacements according to the product specific maintenance schedule.



Drive preventive maintenance is based on ABB's extensive knowledge and experience in manufacturing and maintaining AC drives for more than 30 years and it takes environmental and operational conditions into account. Qualified and certified drive specialists perform preventive maintenance work.

Benefits

- Increased drive reliability
- Optimized maintenance costs and minimized repair costs
- Easy-to-plan maintenance budget
- Extended drive lifetime
- Genuine, factory-certified ABB parts

Service provided

Preventive maintenance service includes labor and the service parts to perform the maintenance work according to the maintenance schedule:

- Visual inspection of the electric drive and its environmental conditions
- Inspection of the connections
- Inspection of the ribbon and fiber optic cables
- Functional inspection of the fan and cooling system
- ESD protected cleaning of the drive
- Inspection of the emergency stop circuit
- Inspection for the prevention of unexpected start-up circuit
- Inspection of the fault logger
- Inspection and storage of the parameters
- Functional testing of the drive under normal conditions

- Basic measurements with supply voltage
- Inspection of the drive spare part inventory
- Reforming of the spare module capacitors

A detailed service report including recommendations for future actions is provided once the maintenance work has been completed and the inspection data fully analyzed.

Ready-made preventive maintenance kits are available at www.abb.com/partsonline for component replacements marked "R" in the maintenance schedule.

Preparations before preventive maintenance

Successfulness of the preventive maintenance depends on the information recorded in the service reports provided by the end-user. The more thorough the information provided by the end-user, the greater the benefit."

ABB must have free access to the drive for maintenance during the shutdown as agreed. Preventive maintenance must be planned well in advance in order to reserve the required resources and service parts.

Product Lifecycle Services

- Installation & Commissioning
- Training
- Support & Remote Services
- Spare Parts & Repairs
- Maintenance & Field Services
- Migration & Retrofits
- Optimization





SP30 EN REV F 2007

Service notes

Maintenance schedule

Based on ABB's experience, failure probability of industrial products equipped with electronic components, such as drives, increases after years of operation. For electric drives this is typically 5 to 10 years. The main reason for failures is aging of components, but it is also greatly affected by the operational conditions. A component failure may cause consequential damage to other parts of the drive including power semiconductors.

A maintenance schedule provides a systematic and functional means of maintaining a specific drive type. It is based on the extensive experience and know-how of manufacturing and maintaining electric drives. Specifications of component suppliers are observed carefully. The environmental and operational conditions of the drive are also considered. A demanding environment, such as high ambient temperature, humidity, dirt and cyclic heavy load, can measurably shorten component lifetime and also maintenance and component replacement intervals.

| | Years from start-up | | | | | | | | | | | | | | | | | | | | | |
|--|---------------------|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|
| | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 |
| Start-up | P | | | | | | | | | | | | | | | | | | | | | |
| Cooling | | | | | | | | | | | | | | | | | | | | | | |
| Air Cooled Unit: | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Internal/additional cooling fan for ACS800-01/-11/-31,104, IP21 and IP55 | | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R |
| ➤ Cooling fan (ACS800-01/-02/-04/-07/-11/-17/-31/-37/-104/DSU) | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| ➤ Cooling fan for TSU | | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R |
| ➤ Enclosure extension cooling fan (ACS800-02) | | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R | I | I | R |
| ➤ Extra cooling fans inside cabinet (ACS800-x7, ACS800 md) | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| ➤ Extra IP54 cooling fan on roof of cabinet (ACS800-07, ACS800 md) | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| Liquid Cooled Unit: | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Cooling fans | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| ➤ Add coolant inhibitor | | I | P | I | P | I | P | I | P | I | P | I | P | I | P | I | P | I | P | I | P | I |
| ➤ Heat exchanger | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| ➤ Cooling water pump | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| ➤ Cooling water pipe connections | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| Aging | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Electrolytic capacitors (DC circuit) | | | | | | | | | | R | | | | | | | | | R | | | |
| ➤ Memory backup battery replacement in the APBU-xx unit | | I | I | I | I | I | R | I | I | I | I | R | I | I | I | I | I | I | R | I | I | I |
| Connections & Surroundings | | | | | | | | | | | | | | | | | | | | | | |
| ➤ AINT+ flat cables | | | | | | | | | | R | | | | | | | | | R | | | |
| ➤ Tightness of terminals | | | | | | | I | | | | | I | | | | | | | I | | | |
| ➤ Quick connector of the converter module (ACS800-x7/ and ACS800 md) | | | | | | | I | | | | | I | | | | | | | I | | | |
| ➤ Door filters (IP20 ... 42) | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| ➤ Door filters (IP54 and above) | | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R | R |
| ➤ Condition of contactors | | | | | | | I | | | | I | | | | | I | | | I | | | I |
| ➤ Fiber optic cables (connections) | | | | | | | I | | | | I | | | | | I | | | I | | | I |
| ➤ Dustiness, corrosion and temperature | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| ➤ Quality of supply voltage | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| Improvements | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Based on product notes | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| Measurements | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Basic measurements with supply voltage | | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P |
| Spare Parts | | | | | | | | | | | | | | | | | | | | | | |
| ➤ Spare parts | | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I | I |
| ➤ DC circuit capacitors reforming | | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P | P |

Note! Recommended service intervals and component replacements are based on the operational environment specified by ABB. ABB recommends drive inspections to be carried out annually to ensure the highest reliability and optimum performance. More information in service instructions, product manuals and on the Internet pages.

Legend:

- R = Replacement of component (At rated load and ambient conditions)
- I = Inspection (visual inspection, correction and replacement if needed)
- P = Performance of on-site work (commissioning, tests, measurements, etc.)



ABB Oy
 Product Support
 PO Box 116
 FI-00381 Helsinki, Finland
 Tel: +358 10 2211
 Fax: +358 10 222 6800
 www.abb.com/drives
 e-mail: sales.productsupport@fi.abb.com