



<b>Test Report</b>					Cert. No. LCIE 10 ATEX 3092 X				
Customer:					Date of Issue				
Customer ref.:					Type: M3GP 100LB 4 Protection Ex nA II T3 type: Serial no.: Tag no.: Order no.:				
Rating: 3-Motor		Product Code 3GGP102520_SH							
		V	Hz	kW	r/min	A	cos φ		
Insul.cl. F		400 Y	50	3	1442	6	0.83		
S1		230 D	50	3	1442	10,6	0.83		
IP 55		380 Y	50	3	1430	6,3	0.85		
63 kg		220 D	50	3	1430	10,9	0.85		
		415 Y	50	3	1444	5,8	0.82		
		440 Y	60	3,5	1729	6,2	0.85		
Resistance			Insulation resistance			Overload test			
U <sub>1</sub> -V <sub>1</sub> 3,105 Ω			24000 MΩ 1000 V			1,6 x T <sub>N</sub> 15s			
U <sub>1</sub> -W <sub>1</sub> 3,104 "			46,0°C			Starting Current I <sub>S</sub> /I <sub>N</sub> = 7,29			
V <sub>1</sub> -W <sub>1</sub> 3,104 "			High-voltage test						
			1800 V 60s						
Test		Line		Input		Output			
		U[V]	f[Hz]	I[A]	P <sub>1</sub> [kW]	P <sub>2</sub> [kW]	n[r/min]	cos φ	η [%]
No-load test		400,0 Y	50	3,145	0,197			0,0906	
Locked-rotor test		74,1 Y	50	6,014	0,426			0,5523	
Temperature-rise test		400,3 Y	50	6,12	3,50	3,00	1444	0,825	85,8
Temperature rise at amb.temp. 25,0°C			Temperature rise at amb. temp. 25,0°C			Measurement method			
[K] Method			[K] Method			1 Resistance			
Stator winding 48,7 1			Frame 30,9 3			2 Embedded temperature detector			
			Bearing D-end 31,0 3			3 Thermometer			
<p>These tests have been carried out on motor no. 3GF11060778B, on date 2011-05-23, which is identical in design with the above.</p> <p>Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.</p>									
On behalf of customer									
On behalf of manufacturer									
ABB Oy, Motors and Generators, Vaasa, Finland									