

May 7, 2007

ABB Automation GmbH  
Schillerstr. 72  
Minden, DE, 32425  
Germany


Dear Michael Gienke,

The Fieldbus Foundation is pleased to inform you that ABB Automation GmbH has successfully completed the Fieldbus Foundation's Host Interoperability Support Test Procedure (FF-569) and has demonstrated support of the features so indicated on the attached exhibit A.

Effective immediately ABB Automation GmbH is granted the right to use the term "successfully completed" for the product and features identified on the exhibit in the promotion and marketing of this product.

Specifically excluded from this grant is the right to claim "certification or approval" by the Foundation in any form or format.

Congratulation and Best Regards,



Richard J. Timoney  
President & CEO  
Fieldbus Foundation

## Exhibit A: Host Implementation Conformance Feature Checklist

Host System:	
Manufacturer:	ABB Automation GmbH
Model:	Industrial IT System 800xA
Type:	AC 800M based
Revision:	SV5.0
Serial No:	N/A
Comm. Profile Class:	21pskvc+22lt+23+24
H1 Stack:	
Manufacturer:	Softing
Revision:	1.20
Test Campaign Number:	CT0054FF
HSE Stack:	
Manufacturer:	Softing
Revision:	5.35
Test Campaign Number:	HT000401

H1 Features	H1 Interface:	HSE via LD:
Device Tag Assignment	Not Run	Passed
Device Address Assignment	Not Run	Passed
Configuration of Link Master Devices	Not Run	Passed

HSE Features	Supported:
HSE Network Infrastructure Support	Passed
Device D2 Redundancy Support	Not Run
Device D3 Redundancy Support	Passed
Interface Redundancy Support	Not Run
HSE LD Support: H1 Configuration Access (42a1)	Passed
HSE LD Support: H1 Configuration Access (42a2)	Not Run
HSE LD Support: Report Redistribution	Passed
HSE LD Support: Republishing	Passed

Function Block Features	H1 Support: Yes/No	HSE Support: Yes/No
Block Tag Configuration	Passed	Not Run
Block Instantiation	Passed	Not Run
Standard Blocks	Passed	Not Run
Enhanced Blocks	Passed	Not Run
Custom Blocks	Passed	Not Run
Function Block Linkage Configuration	Passed	Not Run
FF Alert Configuration	Passed	Not Run
FF Alert Handling	Passed	Not Run
FF Multi-bit Alert Handling	Not Run	Not Run
FF Trend Configuration	Not Run	Not Run
FF Trending Handling	Not Run	Not Run
Device Description Services	Passed	Not Run
DD Method Execution	Not Run	Not Run
DD Menu	Not Run	Not Run
DD Edit Displays	Not Run	Not Run
Capability Files	Passed	Not Run
Multi Variable Optimization	Not Run	Not Run
Software Download	Not Run	Not Run
Flexible Function Block – Fixed OD	Not Run	Not Run
Flexible Function Block – Variable OD	Not Run	Not Run
Device Replacement	Passed	Not Run